

**HYDERABAD DISASTER RESPONSE AND ASSET PROTECTION AGENCY
(HYDRAA)**



From
The Commissioner,
Hyderabad Disaster Response,
And Asset Protection Agency,
(HYDRAA)

To
The Management
Sri Vidya Secondary School
D. No. 2-2-1105/26/1, 2-2-1105/26/2
& 2-2-1105/26/3, Tilaknagar,
New Nallakunta, Hyderabad.

RC.No.642/COMM/HYDRAA/2025, Dated: 25.06.2026.

Sub : - HYDRAA - Disaster Management Wing - Existing non high-rise building of Sri Vidya Secondary School consisting of Ground + 3 Upper Floors situated at D. No. 2-2-1105/26/1, 2-2-1105/26/2 & 2-2-1105/26/3, Tilaknagar, New Nallakunta, Hyderabad - **Renewal of Fire No Objection Certificate - Issued** - Regarding.

- Ref : -
- 1) Proceeding Rc. No. 5041/B2/97, Dated: 12.03.2010 of the Director General of the State Disaster Response and Fire Services, A.P., Hyd.
 - 2) Proceedings No. DM/0011/2018/D(VK) EVDM/2018, dt. 29.06.2018 of the Commissioner, GHMC.
 - 3) G.O.MS.No. 99, MA&UD, (GHMC.I) Department, Dt: 19-07-2024.
 - 4) Renewal of Fire NOC Rc.No.642/COMM./HYDRAA/2025, Dated: 15.09.2025 issued by the Commissioner, HYDRAA.
 - 5) Application of the management, received through Inward No.615, dt: 05.06.2026 of the Commissioner, HYDRAA.
 - 6) Inspection report date: 22.06.2026.

*** **

1. Vide reference 4th cited, the renewal of Fire No Objection Certificate was issued to the Existing non high-rise building of Sri Vidya Secondary School consisting of Ground + 3 Upper Floors situated at D. No. 2-2-1105/26/1, 2-2-1105/26/2 & 2-2-1105/26/3, Tilaknagar, New Nallakunta, Hyderabad.
2. Vide reference above 5th cited, the building owner/occupier has applied now, for further renewal of Fire No Objection Certificate.
3. Vide reference above 6th cited, the team has inspected the above building and submitted the following report.
4. Particulars of the Building:

a)	Name & Address of the building	Sri Vidya Secondary School D. No. 2-2-1105/26/1, 2-2-1105/26/2 & 2-2-1105/26/3, Tilaknagar, New Nallakunta, Hyderabad
b)	Plot Area/Height	1539.35 Sq. Meters/13.30 Meters
c)	Abutting Road Width	12.00 Meters
d)	No of floors	Ground + 3 Upper Floors
e)	Name of the Owner/ Occupier & Mobile no.	The Management, Mobile no.9542995461
f)	Map Location	17.39186 78.508943

5. Floor wise details:

Sl. No.	Floor	Area in Sq. Meters	Type of Occupancy	Max Occupant Load
1	Ground Floor	815.79	Educational (B-1)	204
2	First Floor	815.79	Educational (B-1)	204
3	Second Floor	815.79	Educational (B-1)	204
4	Third Floor	815.79	Educational (B-1)	204
Total		3263.16	-	-

6. Open Spaces all around the building:

Sl. No.	Directions	Required as per Hon'ble Supreme Court Orders	Provided	Remarks
1	Front (S)	6.00 Meters	5.20 Meters	The building was constructed very long back & far before Fire Service Act 1999 i.e., in 1980s
2	Side I (E)	6.00 Meters	0 to 4.30 Meters	
3	Side II (W)	6.00 Meters	2.80 Meters	
4	Rear (N)	6.00 Meters	2.10 Meters	

7. Means of escape:

Sl. No.	Required			Provided		Deficit
	Staircases	Nos.	Width	Nos.	Width	
1	Internal / External	02	2 X 1.50 Meters = 3.00 Meters	03	1 X 1.30 Meters 1 X 1.35 Meters 1 X 1.20 Meters = 3.85 Meters	Nil

8. The Minimum Fire Safety Installations required & provided as per Table 7 of Part-4 of N.B.C of India 2016:

Sl. No.	Fire Safety Installations	Required	Provided	Deficit
1	Fire Extinguishers	16 Nos.	16 Nos.	Nil
2	First Aid Hose Reel	04 Nos.	04 Nos.	Nil
3	Underground Tank	NR	50,000 Liters	Nil
4	Terrace Tank	10,000 Liters	10,000 Liters	Nil
5	Pump at the Terrace Tank level	1 No. Booster Pump of 450 LPM	1 No. Booster Pump of 450 LPM	Nil

Terms & Conditions: -

1. The Fire NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules / Govt. Orders as applicable.
2. Fixed and first-aid Fire Fighting equipment, alarm etc shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and half yearly after two Years. Also expired equipment should be replaced immediately.

3. Emergency power generator etc., and associated equipment should be tested periodically, verified as per NBC, and IS-1646.
4. Adequate ventilation should be provided in all floors of the building.
5. Every room with a capacity of 45 students shall be provided with two doorways.
6. Evacuation plan at showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited all times, all escape /exit routes shall not be blocked or encroached.
7. Fresh NOC would be required for any change in occupancy or additions/ alterations in the building structure as per NBC of India and building bye/laws.
8. The Management has to maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.
9. Any Loss of life or property due to Non - functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
10. All the Occupants must know the correct method of operation of the First Aid Fire Fighting System installed.
11. All Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
12. This Fire No Objection Certificate is **valid for one year** from the date of issue i.e. from 16.09.2026 to 16.09.2027 and it is the responsibility of the builder/occupier to apply for the next Renewal, two months before expiry of this Renewal of Fire NOC.

In view of the above, the **Renewal of Fire No Objection Certificate** is issued to the Existing non high-rise building of Sri Vidya Secondary School consisting of Ground + 3 Upper Floors situated at D. No. 2-2-1105/26/1, 2-2-1105/26/2 & 2-2-1105/26/3, Tilaknagar, New Nallakunta, Hyderabad.

Commissioner,
Hyderabad Disaster Response &
Asset Protection Agency.
Commissioner
HYDRAA